



DECLARATION OF PERFORMANCE

According to Construction Products Regulation EU N° 305/2011

N° 0051 – CPD - 0267

1. Unique identification code of the product-type:
TUL375EN – POWER SUPPLY EQUIPMENT
2. Type, batch or serial number or any other element allowing identification of the construction product as required pursuant to Article 11(4):
TUL375EN
3. Intended use or uses of the construction product, in accordance with the applicable harmonised technical specification, as foreseen by the manufacturer:
FIRE DETECTION AND FIRE ALARM SYSTEMS INSTALLED IN BUILDINGS
4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required pursuant to Article 11(5):
VENITEM srl via Del lavoro, 10 – 30030 Salzano (VE)
5. Where applicable, name and contact address of the authorised representative whose mandate covers the tasks specified in Article 12(2):
Not Applicable
6. System or systems of assessment and verification of constancy of performance of the construction product as set out in Annex V:
System 1
7. In case of the declaration of performance concerning a construction product covered by a harmonised standard:
IMQ S.p.a. 0051
performed type testing, and the initial inspection of the manufacturing plant and of the factory production control with continuous surveillance, assessment and approval of the factory production control under System 1 and issued the EC certificates of conformity
0051-CPD-0267
8. In case of the declaration of performance concerning a construction product for which a European Technical Assessment has been issued:
Not Applicable, see item 7
9. Declared performance
All requirements including all Essential Characteristics and the corresponding performances for the intended use or uses indicated in point 3 above have been determined as described in the EN54-4 mentioned in the table below.



DECLARATION OF PERFORMANCE

11/02/15

DP-AL-T375-01-00

Rev.00

Page 2 of 2

Essential characteristics	Performance	Harmonised technical specification
Performance of power supply	Pass	EN54-4:1997 + A1:2002 + A2:2006 Art.: 4, 5, 6
Operational reliability	Pass	EN54-4:1997 + A1:2002 + A2:2006 Art.: 4, 5, 6, 7, 8
Durability of operational reliability and response delay, temperature resistance	Pass	EN54-4:1997 + A1:2002 + A2:2006 Art.: .9.5
Durability of operational reliability, vibration resistance	Pass	EN54-4:1997 + A1:2002 + A2:2006 Art.: 9.7, 9.8, 9.15
Durability of operational reliability, electrical stability	Pass	EN54-4:1997 + A1:2002 + A2:2006 Art.: da 9.9 a 9.13
Durability of operational reliability, humidity resistance	Pass	EN54-4:1997 + A1:2002 + A2:2006 Art.: 9.6, 9.14

10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by

Manente Marcello; R & D Director

Signature

Salzano, 11th February 2015